

# VOC Content Test Certificate

Tuesday, 15<sup>th</sup> July 2014

Manufacturer: ACT Australia Pty Ltd (93 Links Avenue South, Eagle Farm, QLD 4009)

Sample Description: ADH-22

Date Tested: June 2014 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168

Test Data:

<p style="text-align: center;"><b>Specification</b></p> <p style="text-align: center;"><b>Green Building Council of Australia Green Star Office Design V3 IEQ-13</b></p> <p style="text-align: center;"><b>Green Building Council of Australia Green Star Office Interiors V1.1 IEQ-11</b></p>	<p><b>ADH-22</b></p>
<p style="text-align: center;">Ceramic tile adhesive</p> <p style="text-align: center;">65 grams per Litre as VOC content per material</p>	<p><b>&lt;1 grams per Litre as VOC content per material</b></p>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Nick Joy  
BSc(Hons)  
Consultant

**CV140634a**