

VOC Content Test Certificate

Tuesday, 15th July 2014

Manufacturer: ACT Australia Pty Ltd (93 Links Avenue South, Eagle Farm, QLD 4009)

Sample Description: SCR-100

Date Tested: June 2014 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168

Test Data:

<p align="center">Specification</p> <p align="center">Green Building Council of Australia Green Star Office Design V3 IEQ-13</p> <p align="center">Green Building Council of Australia Green Star Office Interiors V1.1 IEQ-11</p>	<p align="center">SCR-100</p>
<p align="center">Ceramic tile adhesive</p> <p align="center">65 grams per Litre as VOC content per material</p>	<p align="center"><1 grams per Litre as VOC content per material</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant

CV140634a